

MODEL : PSC-100B

OUTPUT FUNCTION TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT	VERDICT
1	RIPPLE & NOISE	V1 : 100 mVp-p (Max)	I/P : 230VAC O/P : FULL LOAD Ta : 25°C	V1 : 20.4 mVp-p (Max)	P
2	OUTPUT VOLTAGE ADJUST RANGE	CH1 : 24 V- 29 V	I/P : 230 VAC I/P : 115 VAC O/P : MIN LOAD Ta : 25°C	23.22 V- 30.02 V/ 230 VAC 23.22 V- 30.02 V/115VAC	P
3	OUTPUT VOLTAGE TOLERANCE	V1 : 1 %- -1 % (Max)	I/P : 115 VAC / 264 VAC O/P : FULL/ MIN LOAD Ta : 25°C	V1 : 0.16 %- -0.16 %	P
4	LINE REGULATION	V1 : 0.5 %- -0.5 % (Max)	I/P : 115VAC ~ 264 VAC O/P : FULL LOAD Ta : 25°C	V1 : 0.07 %- -0.07 %	P
5	LOAD REGULATION	V1 : 0.5 %- -0.5 % (Max)	I/P : 230 VAC O/P : FULL/MIN LOAD Ta : 25°C	V1 : 0.16 %- -0.16 %	P
6	SET UP TIME	230VAC : 2400 ms (Max) 115 VAC : 2400 ms (Max)	I/P : 230 VAC I/P : 115 VAC O/P : FULL LOAD Ta : 25°C	230VAC/ 1693 ms 115VAC/ 1693 ms	P
7	RISE TIME	230VAC : 30 ms (Max) 115VAC : 30 ms (Max)	I/P : 230 VAC I/P : 115 VAC O/P : FULL LOAD Ta : 25°C	230VAC/ 19.6 ms 115VAC/ 20.8 ms	P
8	HOLD UP TIME	230VAC : 40 ms (TYP) 115VAC : 15 ms (TYP)	I/P : 230 VAC I/P : 115 VAC O/P : FULL LOAD Ta : 25°C	230VAC/ 90 ms 115VAC/ 19 ms	P
9	OVER/UNDERSHOOT TEST	< ±5%	I/P : 230 VAC O/P : FULL LOAD Ta : 25°C	TEST : < 5 %	P
10	DYNAMIC LOAD	V1 : 2760 mVp-p	I/P : 230 VAC O/P : FULL /Min LOAD 90% DUTY/1KHZ Ta : 25°C	190 mVp-p	P
11	CH2 BAT. CHARGE CURRENT	1.25A (TYP)	I/P : 230 VAC O/P : CH1:FULL LOAD CH2:BAT. Ta : 25°C	1.355 A	P

**INPUT FUNCTION TEST**

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT	VERDICT
1	INPUT VOLTAGE RANGE	90VAC~264 VAC	I/P : TESTING O/P : FULL LOAD Ta : 25°C	49 V~264V	P
			I/P : LOW-LINE-3V= 87 V HIGH-LINE+15%=300 V O/P : FULL/MIN LOAD ON : 30 Sec . OFF : 30 Sec 10MIN ( AC POWER ON/OFF NO DAMAGE )	TEST : OK	
2	INPUT FREQUENCY RANGE	47HZ ~63 HZ NO DAMAGE OSC	I/P : 90VAC ~ 264 VAC O/P : FULL-MIN LOAD Ta : 25°C	TEST : OK	P
4	EFFICIENCY	88% (TYP)	I/P : 230 VAC O/P : FULL LOAD Ta : 25°C	92.4 %	P
5	INPUT CURRENT	230V/ 1.2 A (TYP) 115V/ 2 A (TYP)	I/P : 230 VAC I/P : 115 VAC O/P : FULL LOAD Ta : 25°C	I = 0.898 A/ 230 VAC I = 1.386 A/ 115 VAC	P
6	INRUSH CURRENT	230V/ 70 A (TYP) 115V/ 35 A(TYP) COLD START	I/P : 230 VAC I/P : 115 VAC O/P : FULL LOAD Ta : 25°C	I = 42 A/ 230 VAC I = 21 A/ 115 VAC	P
7	LEAKAGE CURRENT	< 1 mA / 240 VAC	I/P : 264 VAC O/P : Min LOAD Ta : 25°C	L-FG : 0.85 mA N-FG : 0.75 mA	P

**PROTECTION FUNCTION TEST**

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT	VERDICT
1	OVER LOAD PROTECTION	105%- 150 %	I/P : 230 VAC I/P : 115 VAC O/P : TESTING Ta : 25°C	137 %/ 230 VAC 121 %/ 115 VAC Hiccup Mode	P
2	OVER VOLTAGE PROTECTION	CH1 : 28.98V~ 37.26 V	I/P : 230 VAC I/P : 115 VAC O/P : MIN LOAD Ta : 25°C	32.34V/ 230 VAC 32.34V/ 115 VAC Hiccup Model	P
3	BATTERY CUT OFF	20V ± 1 V	I/P : 230 VAC O/P : FULL LOAD Ta : 25°C	19.5 V/230VAC	P
4	SHORT PROTECTION	SHORT EVERY OUTPUT 1 HOUR NO DAMAGE	I/P : 264 VAC O/P : FULL LOAD Ta : 25°C	NO DAMAGE Hiccup Mode	P

**CONTROL FUNCTION TEST**

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT	VERDICT
1	AC OK	Relay contact output, ON : AC OK ; OFF : AC Fail ; Max. Rating : 30V / 1A	I/P : 230 VAC O/P : FULL LOAD Ta : 25°C	OK	P
2	BATTERY LOW	Relay contact output, ON : Battery OK ; OFF : Battery Low ; Max. Rating : 30V / 1A Battery low voltage : < 22V	I/P : 230 VAC O/P : MINLOAD Ta : 25°C	20V	P



**SAFETY TEST**

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT	VERDICT
1	WITHSTAND VOLTAGE	I/P-O/P : 3 KVAC/min I/P-FG : 1.5 KVAC/min O/P-FG : 0.5 KVAC/min	I/P-O/P : 3.6 KVAC/min I/P-FG : 1.8 KVAC/min O/P-FG : 0.6 KVAC/min Ta : 25°C	I/P-O/P : 1.43 mA I/P-FG : 3.31 mA O/P-FG : 0.321 mA NO DAMAGE	P
2	ISOLATION RESISTANCE	I/P-O/P : 500VDC>100MΩ I/P-FG : 500VDC>100MΩ O/P-FG : 500VDC>100MΩ	I/P-O/P : 500 VDC I/P-FG : 500 VDC O/P-FG : 500 VDC Ta : 25°C/70%RH	I/P-O/P : 30 GΩ I/P-FG : 30 GΩ O/P-FG : 30 GΩ NO DAMAGE	P
3	APPROVAL	TUV : Certificate NO : E183223 UL : File NO : R50155036			P

**E.M.C TEST**

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT	VERDICT
1	HARMONIC	EN61000-3-2 CLASS A	I/P : 220/230 /240VAC/50HZ O/P : 100/75/50/25%LOAD Ta : 25°C	PASS	P
2	CONDUCTION	EN55022 CLASS B	I/P : 230 VAC (50HZ)/115V(60HZ) O/P : FULL/50% LOAD Ta : 25°C	PASS Test by certified Lab	P
3	RADIATION	EN55022 CLASS B	I/P : 230 VAC(50HZ) /115V(60HZ) O/P : FULL LOAD Ta : 25°C	PASS Test by certified Lab	P
4	E.S.D	EN61000-4-2 LIGHT INDUSTRY AIR : 8KV / Contact : 4KV	I/P : 230 VAC/50HZ O/P : FULL LOAD Ta : 25°C	CRITERIA A	P
5	E.F.T	EN61000-4-4 LIGHT INDUSTRY INPUT : 1KV	I/P : 230 VAC/50HZ O/P : FULL LOAD Ta : 25°C	CRITERIA A	P
6	SURGE	IEC61000-4-5 LIGHT INDUSTRY L-N : 1KV L,N-PE : 2KV	I/P : 230 VAC/50HZ O/P : FULL LOAD Ta : 25°C	CRITERIA A	P
7	Test by certified Lab & Test Report Prepare				

**M.T.B.F & LIFE CYCLE CALCULATION**

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT	VERDICT
1	CAPACITOR LIFE CYCLE	PSC-100A : SUPPOSE C101 IS THE MOST CRITICAL COMPONENT	I/P : 230VAC O/P : FULL LOAD Ta= 25 °C LIFE TIME= 191623.7 HRS I/P : 230VAC O/P : FULL LOAD Ta= 50 °C LIFE TIME= 46297.3 HRS		P
2	MTBF	MIL-HDBK-217F NOTICES2 PARTS COUNT TOTAL FAILURE RATE : 417.6 KHRS			P

**COMPONENT STRESS TEST**

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT	VERDICT
1	Power Transistor (D to S) or (C to E) Peak Voltage	Q 1 Rated SPA11N65C3 11A/650V	I/P : High-Line +3V = 267 V O/P : (1)Full Load Turn on (2) Output Short Ta : 25°C	(1) 588 V (2) 508 V	P
2	Diode Peak Voltage	Q101Rated IRF3415 43A/150V	I/P : High-Line +3V = 267 V O/P : (1)Full Load Turn on (2)Output Short Ta : 25°C	(1) 121 V (2) 91 V	P
3	Clamp Diode Peak Voltage	D2 Rated 1A/1KV 1N4007GP	I/P : High-Line +3V = 267 V O/P : (1) Dynamic Load 90%DUTY/ 1KHz Ta : 25°C	(1) 456 V	P
4	Input Capacitor Voltage	C 5 Rated 100u/400V 105°C 18*25 KMG	I/P : High-Line +3V = 267 V O/P : (1)Full Load Turn on /Off (2) Min load Turn on /Off (3)Full Load /Min load Change Ta : 25°C	(1) 371.8 V (2) 379.8 V (3) 379.9 V	P
5	Control IC Voltage Test	U1Rated CONTROL TEA1552 9.3V~20V	I/P : High-Line +3V = 267 V O/P : (1)Full Load Turn on /Off (2) Min load Turn on /Off (3)Full Load /Min load Change Ta : 25°C	(1) 12.434 V (2) 11.692 V (3) 11.692 V	P

DATE	SAMPLE	TEST RESULT	TESTER	APPROVAL
2009/4/7	RD SAMPLE	PASS	SANFORD SU	VINCENT TSENG
2009/6/10	PRODUCT SAMPLE W0904E34	PASS	SANFORD SU	VINCENT TSENG
2009/7/5	PRODUCT SAMPLE W0906D48	PASS	SANFORD SU	VINCENT TSENG

2003/12/12 A50-F023